



- NOTES:
1. YARD LIGHTS ARE MANUAL SWITCHED FOR MAINTENANCE ONLY. ONE LIGHT ON THE SOUTH END OF THE CONTROL HOUSE WILL BE ON A PHOTOEYE.
 2. STRUCTURES 300 AND 301 WILL BE CONVERTED TO DEADEND STRUCTURES.

PRELIMINARY
NOT FOR CONSTRUCTION

REV	DATE	DR	CK	DESCRIPTION
7	07.27.06	PEI	PEI	ISSUED FOR PERMIT
6	07.05.06	PEI	PEI	ISSUED FOR PERMIT
5	06.15.06	PEI	PEI	ISSUED FOR CLIENT REVIEW
4	05.03.06	PLM	MCB	ADDED 115KV BRKRS, WOOD STRUCT & CTL BLDG
3	07.29.04	JTP	RCJ	ADDED 115KV STRUCTURE, BREAKER & BUILDING
2	04.30.99	RCJ	WFH	ADDED 34.5KV STATION ARRESTERS
1	08.11.97	RCJ	WFH	ADDED 115KV INT. LIGHTNING ARRESTERS

VILCO		VERMONT ELECTRIC POWER CO., INC. RUTLAND, VERMONT MIDDLESEX SUBSTATION	
PROPOSED GENERAL ARRANGEMENT PLAN MORERTOWN, VERMONT			
SCALE: 1/8"=1'	DRAWN BY: GBH	APPROVED BY:	DATE
DATE: 07-15-69	CHECKED BY:		
DRAWING NUMBER: PLOT: 1=1	209-6000D		4 REV.

FILE: F:\209\CIVIL\2096000D