

Exhibit Petitioner SSM-2

| K42 Structure Analysis Summary: | | | |
|---|-----|----------------------|------------------|
| | | | Percent of total |
| Reason for replacement: | | Percent of deficient | 214 structures |
| Deficient (Priority ranked 1,2, 3 or 4 w/ 5 being immediate problem) or not meeting 2007 NESC | 55 | 37.93% | 25.70% |
| Not deficient but 1958 (67 yrs old in 2025) | 88 | 60.69% | 41.12% |
| Not deficient but 1966 (59 yrs old in 2025) | 2 | 1.38% | 0.93% |
| Sum | 145 | 100.00% | 67.76% |