
vermont electric power company



Contents

Preceding Events
2021 Cold Weather Event
New England's Posture


System Frequency - Supply and Demand





Source: Balancing and Frequency Control, A Technical Document Prepared by the NERC Resources Subcommittee



Electric Reliability Council of Texas (ERCOT)








Source: North American Electric Reliability Corporation



History 2011 – Southwest Cold Weather Event



- February 1-5, 2011
- Unusual cold weather for the region
- Effected multiple areas
 - Included ERCOT
 - Loss of generation
 - Load shed





History 2011 – Southwest Cold Weather Event




Condition	Consequences	
Coldest Texas weather since 1989	Single-digit sub-freezing temperatures for more than 100 hours with sustained winds of 30–40 mph	
New ERCOT winter peak demand record	56,344 MW (with a second record set the following week)	
ERCOT capacity affected	17.6 percent of total ERCOT winter 2011 capacity out at February 2 peak	
225 units tripped, derated, or failed to start (February 1–3)	Except for nuclear facilities, all power plant types including coal/lignite, simple-cycle gas, combined-cycle gas, and wind resources experienced problems.	

Outcome


NERC developed and released *Reliability Guideline: Generating Unit Winter Weather Readiness* in December of 2012



History 2018 – South Central Cold Weather Event



- January 15-19, 2018
- Unusually cold weather for the region
- Effected multiple areas (excluding ERCOT)
- Natural gas dependency highlighted






History 2018 – South Central Cold Weather Event

Findings

- Failure to properly prepare or "winterize" generation
- Gas supply issues

Figure 48: January 15-19, 2018 – Fuel Type for Unplanned Generation Outages and Derates due to Freezing Issues, for Event Area (by MW of Generation)




Source: FERC and NERC Staff Report

Outcome


Develop or enhance cold weather NERC Standards








Rapid Decrease in Generation Causes Frequency Drop






Generation Capacity Out February 14 – 19, 2021



Generation Capacity Out by Fuel Type






WINTER STORM 2021

Texas was "seconds and minutes" away from catastrophic monthslong blackouts, officials say

texastribune.org





EEA 3 Rotating Outages in Progress Operating Reserves: 3,384 MW Last Updated: Feb 18, 2021 - 06:04

ercot.com



2011 vs. 2021 Event Comparison

	2011	2021
Maximum generation capacity forced out at any given time (MW)	14,702	52,277
Generation forced out one hour before start of EEA3 (MW)	1,182	2,489
Cumulative generation capacity forced out throughout the event (MW)	29,729	46,249*
Cumulative number of generators outaged throughout the event	193	356
Cumulative gas generation de-rated due to supply issues	1,282	9,323
Lowest frequency	59.58	59.30
Maximum load shed requested (MW)	4,000	20,000
Duration load shed request (hours)	7.5	70.5
Estimated peak load (without load shed)	59,000	76,819

ercot.com



Outcome

FERC and NERC investigation

Jim Robb, NERC CEO

- Extreme weather exposed weakness
 - Appropriate design basis for weatherization
- Coal and Fuel Oil units are retiring, natural gas is becoming more relied upon
- Electric and natural gas dependency needs to be fully understood
 - Natural gas systems not winterized
 - Natural gas compressors were not identified as critical and were shed
- More transmission is likely necessary
- Seasonal and Annual assessments have identified this risk
- Texas pivoting from "who to blame" to "how to fix"




New England's Posture – Cold Weather Event





New England's Posture – Cold Weather Event




Source: 2020/2021 Winter Reliability Assessment, NERC.




New England's fuel mix (12/25/17 – 1/9/18)


3/18/2021 Generation (14,500 MW)



12/18/2020 Generation (18,880 MW)




"Cold" NE Generation (18,000 MW)





New England's Natural Gas Pipelines



https://www.eia.gov/naturalgas/review/deliverysystem/2013/



New England's Cold Weather Preparedness

- ISO-NE active monitoring of natural gas supplies
- Encourage dual fuel generation
- Pay for Performance
- Inventoried Energy Program



The Texas event was significant.

Reliance on natural gas presents an ongoing risk to NE during extended cold weather events when firm gas supplies are not guaranteed for generation.

Questions?

