



# New England T & D Technical Forum

---

*Evolving light load, high voltage transmission  
system problems and distribution system  
interaction*

Dean LaForest

MANAGER – REAL TIME STUDIES



# Meeting agenda

- Introductions
- Forum Concept – discussion
- Presentation on New England load power factor, evolving load trends and growing transmission high voltage problems
- Q & A
- Next steps

# FORUM CONCEPT



# Rationale for the group's need

- New England's transmission and distribution systems are going through their most significant function transition in decades
  - A significant portion of energy production for the system is moving from fewer power production facilities on the transmission system to more numerous power production facilities on the distribution system
  - Fossil fueled power production is being minimized / eliminated and being replaced by renewable / non-polluting power production with energy storage
  - The redistribution of supply is changing some long-standing functions supplied / supported by the transmission system, and will significantly change use of the transmission system
  - This evolution is changing how the transmission system and distribution system may interact, so active discussion and improved understanding of how these changes are impacting both transmission and distribution seems a prudent course to take as these changes take place
  - This forum is an attempt to do just that




# THE EVOLVING IMPACT OF ENERGY PRODUCTION CHANGES ON NET LOAD, LOAD POWER FACTOR AND TRANSMISSION VOLTAGE CONTROL




# The “Duck Curve” – New England style


- New England has been working on reducing energy demand and transitioning to more renewable energy for many years
- The impacts of these changes have altered the overall demand, net load and the daily load shape in New England
- The two most significant changes have been on peak and minimum loads
  - Peak loads have not surpassed the all time peak set in the mid 2000s
    - System planning efforts in New England have largely managed the “peak issues”
  - Minimum load levels, especially during daylight hours, have steadily reduced over time, such that day time min loads on spring weekends are the new minimum load levels in New England



# Daytime Min Loads over the past three years




# Animation showing Daytime Loads on 5/3/22



# Impact on unit commitment due to new low daytime loads

- Unit in New England is driven by economics and need
  - Load and export / import from adjoining areas drives internal commitment
  - Reliability commitment is made afterward
- Lower minimum loads drives down commitment of in market generation
  - Generation not in the market (such as DER) is not impacted

Potential area without transmission connected generation for current lightest loads



# LOAD POWER FACTOR IN NEW ENGLAND

# Load Power Factor – Why We Monitor It

- ISO NE began monitoring back in the 1990s
  - At the time, peak load / low voltage was the operating concern
  - Concerns have morphed into light load / high voltage operating concerns (“all lines in” and “facility out”)
- Monitoring included reporting for each area (determined by local voltage performance and TO operating footprint)
- Operating studies were performed to determine what load power factor each area could support reliably
- The “LPF survey” examined 6 selected points to represent the whole year – TOs provided the data
- ISO recently transitioned to examining hourly data for each area using our archived SCADA data to get a more complete picture of performance


# LATEST LPF CURVES

# Load Power Factor Curve background info


- Curves created for each area
- Hourly load power factor monitored at high side load distribution transformer
  - So 115 kV side for a 115 / 34.5 kV transformer
- LPF plotted against two curves
  - Orange curve on the upper left shows allowable “light load / high voltage” curve
    - Points above that line have the potential to cause post-contingent transmission high voltage without added generation commitment or other operating actions
  - Gray curve to the lower right shows allowable “high load / low voltage” curve
    - Points below that line have the potential to cause post-contingent transmission low voltage without added generation commitment or other operating actions




# Maine LPF 2021




# New Hampshire LPF 2021




# Northeast MA LPF 2021




# Rhode Island LPF 2021




# Connecticut LPF 2021





# Southwest Connecticut LPF 2021



# Western Massachusetts LPF 2021




# Central MA / Harriman LPF 2021



ISO-NE PUBLIC

# Vermont LPF 2021



# Transmission Voltage Limits


- Provided by the transmission owners (TOs)
- For high voltage, very few of the TOs allow ANY time above 105% of nominal voltage
- Example table below (take from OP 19, appendix K)

Table 2 - Long Time Emergency Voltage Limits (LTEVL)

| Long Time Emergency Voltage Limits (LTEVL) <sup>1, 2, 3, 4, 8, 9</sup> |                         |                         |                          |                         |                         |                          |                         |                         |                          |
|------------------------------------------------------------------------|-------------------------|-------------------------|--------------------------|-------------------------|-------------------------|--------------------------|-------------------------|-------------------------|--------------------------|
| <u>LCC / TO</u>                                                        | 115 kV                  |                         |                          | 230 kV                  |                         |                          | 345 kV                  |                         |                          |
|                                                                        | Time applicable         | Low voltage limits (kV) | High voltage limits (kV) | Time applicable         | Low voltage limits (kV) | High voltage limits (kV) | Time applicable         | Low voltage limits (kV) | High voltage limits (kV) |
| CONVEX (ES)                                                            | Infinite                | 105.0                   | 121.0                    | N.A.                    | N.A.                    | N.A.                     | Use NORMVL              |                         |                          |
| CONVEX (UI)                                                            | Use NORMVL              |                         |                          | N.A.                    | N.A.                    | N.A.                     | Use NORMVL              |                         |                          |
| Maine (CMP)                                                            | 30 minutes              | 105.8                   | 124.0                    | N.A.                    | N.A.                    | N.A.                     | Use NORMVL              |                         |                          |
| Maine (Versant Power)                                                  | 30 minutes              | 105.8                   | 124.0                    | N.A.                    | N.A.                    | N.A.                     | Use NORMVL              |                         |                          |
| New Hampshire                                                          | 120 minutes             | 107.0                   | 121.0                    | Use NORMVL              |                         |                          | Use NORMVL              |                         |                          |
| NGRID (NGRID and RIE <sup>10</sup> )                                   | 30 minutes              | 103.5                   | 121.0                    | 30 minutes              | 207.0                   | 241.5                    | 30 minutes              | 310.5                   | 362.0                    |
| NSTAR                                                                  | Load cycle <sup>5</sup> | 103.5                   | 121.0                    | Load cycle <sup>5</sup> | 207.0                   | 241.5                    | Load cycle <sup>5</sup> | 310.5                   | 362.0                    |
| VELCO                                                                  | 120 minutes             | 103.5                   | 121.0                    | 120 minutes             | 207.0                   | 241.5                    | 120 minutes             | 310.5                   | 362.0                    |



# Transmission voltage limit example



# LPF AND TRANSMISSION PLANNING

# Load power factor assumptions in Transmission System Planning

- ISO New England has a set of agreed upon assumptions used by all regional planners
- Included among those is the set of load power factors, supplied by each TO, for regional planning
- Light load conditions used an almost universal load power factor assumption
  - For all but the Boston area, a 0.998 leading load power factor is assumed
  - The 0.998 leading power factor yields approximately unity power factor on the high side of distribution transformers

## Regional planning and cost

- New England still supports regionalized cost support for meeting regional transmission needs
- Meeting these needs is premised, in part, on the assumed load power factor in the planning cases
- Actual load power factor in the region (at light loads) can be worse than that assumed in planning cases
- ISO NE is exploring if Operating Procedure 17 (Load Power Factor and System Assessment) should be based upon a reasonable set of load power factors and not what the system as currently designed can support




## EXAMPLE OF CURRENT OPERATIONAL CONCERNS DUE TO POOR LOAD POWER FACTOR




# The system is continuously changing

- Planned maintenance work (transmission and generation) largely is performed in the spring and fall, during lighter system loads
- New generation often requires transmission work to integrate the new generation
- Work is underway to connect Vineyard Wind
  - 122 line outage in April (two weeks)




## Operational concerns arose . . .

- Operating studies indicated when loads were at their daytime min loss of the 399 line was causing post-contingent high voltage on the Cape
- The 122 line was out for planned work
- The 137 line was carrying all load on the outer Cape




# Loads on the Outer Cape (MW and MVARs)

- MW and MVAR loads plotted for the Outer Cape (on the 135 and 115 lines)
- Problem appeared with the reactive demand change (from positive to negative) before Easter (4/9/23)




# Loads on the Outer Cape on Easter (4/9/23)




# ISO NE control room saw post-contingent high voltage

- ISO NE's real time contingency analysis identified the issue
  - Loss of the 399 line placed the Outer Cape on only the 137 line
  - The impact of DER reduced local load from 120 MW at 3 AM to less than 50 MW at 2 PM
  - Local generation was unavailable to turn on to mitigate the issue
  - All local transmission caps were off
  - There were no local reactors
  - Remote reactors were maxed out
  - Luckily, planned generation outages in New England resulted in some somewhat remote generation being on-line (in central MA, Rhode Island and eastern CT) which had a very limited impact on voltage in the Cape
    - To make these units effective, significant deviations from normal voltage schedule were required
    - If these were not committed in economics, the cost to run these units were have been paid for by the local area with the high voltage issue





# Post-contingent power flow model



## How was this managed in real time

- Multiple remote, transmission connected generators were moved to their low voltage limit, going leading pre-contingency to decrease voltage on the Cape by less than 0.5 kV (less than 0.5 %)
- Worked with the local distribution company to first turn off manually switched and then time clock switched caps (6.5 MVARs of the latter found)
- Removing 5 MVAR of the time clock switched caps (manual were already all off) removed the problem
  - Reduced post-contingent transmission voltage on the Cape over 1 kV



## Realizations from this event

- DER impacts on portions of the 115 kV system are starting to impact BES operations during maintenance / construction seasons
- This impact will increase over time as additional DER is installed
- The impact will worsen in areas currently impacted, and will become evident in other areas as they accrue DER
- DER voltage control (or lack thereof) is impacting transmission system performance
- Distribution voltage control and load power factor control is significantly increasing in importance to system reliability



# Questions?

